

EBMUD LEAD IN SCHOOLS SAMPLE RESULTS

| School Name | Location Type | Location Description | Sampled Date | Sample_Type | Result (parts per billion) (ug/L) | Qualifier | MDL | PQL |
|-------------------------------------|---------------|--------------------------------------|--------------|-------------|-----------------------------------|-----------|------|-----|
| Ford Elementary | Tap | Rm 106 | 11/2/2017 | Initial | ND | | 0.10 | 1.0 |
| Ford Elementary | Fountain | Lower by rm 128 and br | 11/2/2017 | Initial | ND | | 0.10 | 1.0 |
| Ford Elementary | Fountain | Lower in multipurpose rm | 11/2/2017 | Initial | ND | | 0.10 | 1.0 |
| Ford Elementary | Tap | Kitchen | 11/2/2017 | Initial | ND | | 0.10 | 1.0 |
| Ford Elementary | Fountain | Lower across rm 212 | 11/2/2017 | Initial | ND | | 0.10 | 1.0 |
| Grant Elementary | Fountain | Left df outside by rm 19 | 11/2/2017 | Initial | 0.79 | J | 0.10 | 1.0 |
| Grant Elementary | Fountain | Lower outside rm 28 | 11/2/2017 | Initial | 0.12 | J | 0.10 | 1.0 |
| Grant Elementary | Fountain | Left outside rm 4 and 6 | 11/2/2017 | Initial | 2.1 | | 0.10 | 1.0 |
| Grant Elementary | Fountain | Lower across Lab | 11/2/2017 | Initial | 0.34 | J | 0.10 | 1.0 |
| Grant Elementary | Fountain | Lower across rm 23 | 11/2/2017 | Initial | 1.4 | | 0.10 | 1.0 |
| Riverside Elementary | Fountain | Lower outside rm 9 and 10 | 11/3/2017 | Initial | ND | | 0.10 | 1.0 |
| Riverside Elementary | Fountain | Taller in multipurpose rm | 11/3/2017 | Initial | 0.22 | J | 0.10 | 1.0 |
| Riverside Elementary | Fountain | Lower outside rm 4 and 5 | 11/3/2017 | Initial | ND | | 0.10 | 1.0 |
| Riverside Elementary | Fountain | Right df outside by rm 17 | 11/3/2017 | Initial | ND | | 0.10 | 1.0 |
| Riverside Elementary | Fountain | Df rm 23 sink | 11/3/2017 | Initial | 1.4 | | 0.10 | 1.0 |
| West County Mandarin | Fountain | Taller outside by multipurpose room | 11/3/2017 | Initial | 0.69 | J | 0.10 | 1.0 |
| West County Mandarin | Tap | Inside multipurpose room | 11/3/2017 | Initial | 4.6 | | 0.10 | 1.0 |
| West County Mandarin | Fountain | Df in rm 12 sink | 11/3/2017 | Initial | 0.15 | J | 0.10 | 1.0 |
| West County Mandarin | Fountain | Taller outside rm 7 and 8 | 11/3/2017 | Initial | 0.36 | J | 0.10 | 1.0 |
| West County Mandarin | Fountain | Df in rm 10 | 11/3/2017 | Initial | 4.4 | | 0.10 | 1.0 |
| Wilson Elementary | Fountain | In multipurpose rm | 11/3/2017 | Initial | 0.64 | J | 0.10 | 1.0 |
| Wilson Elementary | Fountain | Lower outside rm 4 | 11/3/2017 | Initial | 0.96 | J | 0.10 | 1.0 |
| Wilson Elementary | Fountain | Left df outside between K1 and K2 | 11/3/2017 | Initial | 0.21 | J | 0.10 | 1.0 |
| Wilson Elementary | Fountain | Lower by rm 16 | 11/3/2017 | Initial | 0.23 | J | 0.10 | 1.0 |
| Wilson Elementary | Fountain | Df in rm 26 sink | 11/3/2017 | Initial | 0.27 | J | 0.10 | 1.0 |
| Nystrom Elementary | Fountain | Lower outside rm 104 | 11/7/2017 | Initial | ND | | 0.10 | 1.0 |
| Nystrom Elementary | Fountain | Lower outside rm 134 | 11/7/2017 | Initial | ND | | 0.10 | 1.0 |
| Nystrom Elementary | Fountain | Lower by rm 234 | 11/7/2017 | Initial | ND | | 0.10 | 1.0 |
| Nystrom Elementary | Fountain | Lower by rm 207 | 11/7/2017 | Initial | ND | | 0.10 | 1.0 |
| Nystrom Elementary | Fountain | Lower by multipurpose rm | 11/7/2017 | Initial | ND | | 0.10 | 1.0 |
| John F. Kennedy High | Fountain | Df by rm 209 | 11/8/2017 | Initial | 0.51 | J | 0.10 | 1.0 |
| John F. Kennedy High | Fountain | By rm 201 | 11/8/2017 | Initial | 0.5 | J | 0.10 | 1.0 |
| John F. Kennedy High | Fountain | Upper DF Between RM 408 & 406 | 11/8/2017 | Initial | 0.5 | J | 0.10 | 1.0 |
| John F. Kennedy High | Fountain | DF Between Room 507 & Staff Restroom | 11/8/2017 | Initial | 0.15 | J | 0.10 | 1.0 |
| John F. Kennedy High | Fountain | DF Between Office Rm & Gym | 11/8/2017 | Initial | 0.9 | J | 0.10 | 1.0 |
| Martin Luther King, Jr. Elementary | Fountain | Lower df by rm 192 | 11/8/2017 | Initial | ND | | 0.10 | 1.0 |
| Martin Luther King, Jr. Elementary | Fountain | Df Rm 208 Sink | 11/8/2017 | Initial | ND | | 0.10 | 1.0 |
| Martin Luther King, Jr. Elementary | Fountain | Df rm 179 sink | 11/8/2017 | Initial | ND | | 0.10 | 1.0 |
| Martin Luther King, Jr. Elementary | Fountain | Lower DF by rm 154 | 11/8/2017 | Initial | ND | | 0.10 | 1.0 |
| Martin Luther King, Jr. Elementary | Fountain | Df in rm 114 sink | 11/8/2017 | Initial | ND | | 0.10 | 1.0 |
| Stege Elementary | Fountain | Lower DF Outside media center | 11/8/2017 | Initial | ND | | 0.10 | 1.0 |
| Stege Elementary | Tap | Kf in faculty rm | 11/8/2017 | Initial | ND | | 0.10 | 1.0 |
| Stege Elementary | Tap | Tap below df outlet rm 19 sink | 11/8/2017 | Initial | 10 | | 0.10 | 1.0 |
| Stege Elementary | Fountain | Lower DF front of Multipurpose rm | 11/8/2017 | Initial | ND | | 0.10 | 1.0 |
| Stege Elementary | Fountain | DF Room 27 | 11/8/2017 | Initial | 1.2 | | 0.10 | 1.0 |
| Leadership Public Schools: Richmond | Tap | Tap in kitchen | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Leadership Public Schools: Richmond | Fountain | Taller by A127 | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Leadership Public Schools: Richmond | Fountain | Taller across rm A236 | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Leadership Public Schools: Richmond | Fountain | Taller across A330 | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Leadership Public Schools: Richmond | Fountain | Tap in rm 305 | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Greenwood Academy | Fountain | Taller across C148 | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Greenwood Academy | Fountain | Left tap in kitchen | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Greenwood Academy | Fountain | Taller across C214 | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Greenwood Academy | Fountain | Taller by rm B112 | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Greenwood Academy | Fountain | Taller by rm B214 | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Nutrition Center | Tap | Tap by loading dock office | 11/9/2017 | Initial | 0.35 | J | 0.10 | 1.0 |
| Nutrition Center | Tap | Tap on right in wash room | 11/9/2017 | Initial | 0.45 | J | 0.10 | 1.0 |
| Nutrition Center | Tap | Tap in kitchen | 11/9/2017 | Initial | 0.25 | J | 0.10 | 1.0 |
| Nutrition Center | Tap | Tap in courtyard cafe | 11/9/2017 | Initial | ND | | 0.10 | 1.0 |
| Nutrition Center | Fountain | Tap behind Bay 6 | 11/9/2017 | Initial | 0.15 | J | 0.10 | 1.0 |
| Verde Elementary | Fountain | Lower across L18 | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Verde Elementary | Fountain | Df in multipurpose rm | 11/14/2017 | Initial | 0.12 | J | 0.10 | 1.0 |
| Verde Elementary | Fountain | Left df across D15 outside | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Verde Elementary | Fountain | Left across D18 outside | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Verde Elementary | Fountain | Left df across C13 | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Lake Elementary | Fountain | Df in rm 21 | 11/14/2017 | Initial | 0.82 | J | 0.10 | 1.0 |
| Lake Elementary | Fountain | Left outside by women's rm | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Lake Elementary | Fountain | Left outside by men's rm | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Lake Elementary | Fountain | Lower df outside by rr | 11/14/2017 | Initial | 0.17 | J | 0.10 | 1.0 |
| Lake Elementary | Fountain | Tap in kitchen | 11/14/2017 | Initial | 2.9 | | 0.10 | 1.0 |
| Bayview Elementary | Fountain | Lower between A1 & A2 | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Bayview Elementary | Fountain | Left df outside by D21 | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Bayview Elementary | Fountain | Left df by storage rm outside | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Bayview Elementary | Fountain | Left df outside by M1 | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Bayview Elementary | Fountain | Lower behind M5 outside | 11/14/2017 | Initial | ND | | 0.10 | 1.0 |
| Montalvin Manor Elementary | Fountain | Lower across 155 | 11/15/2017 | Initial | 0.23 | J | 0.10 | 1.0 |
| Montalvin Manor Elementary | Fountain | Left outside across 209 | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Montalvin Manor Elementary | Fountain | Left outside across playground | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Montalvin Manor Elementary | Fountain | Lower across 175 | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Montalvin Manor Elementary | Fountain | Lower in multipurpose room | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Shannon Elementary | Fountain | Df by office | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Shannon Elementary | Fountain | Left outside by rm 13 | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Shannon Elementary | Fountain | Left behind rm 4 outside | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Shannon Elementary | Fountain | Left behind rm 10 | 11/15/2017 | Initial | 1.6 | | 0.10 | 1.0 |
| Shannon Elementary | Tap | Sink in multipurpose rm | 11/15/2017 | Initial | 1.1 | | 0.10 | 1.0 |
| Tara Hills Elementary | Fountain | Lower across admin | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Tara Hills Elementary | Fountain | Lower outside across rm 22 | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Tara Hills Elementary | Fountain | Lower behind 17 outside | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Tara Hills Elementary | Fountain | Df in N3 sink | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |
| Tara Hills Elementary | Fountain | Lower in multipurpose rm | 11/15/2017 | Initial | ND | | 0.10 | 1.0 |

ND = Analyte not detected at or above MDL (Maximum Detection Limit)
 J = Indicates result is an estimated concentration, detected but not quantified
 MDL = Method Detection Limit
 PQL = Practical Quantitation Limit
 EPA Method 200.8